



**RFP ADDENDUM #1**

**CONTRACT NAME: Generator Maintenance & Repairs**

**PROJECT NUMBER: SK120721**

**DATE OF ADDENDUM #1: March 29, 2022**

**The following information shall be carefully examined, together with the Contract Documents, and all information listed in this Addendum shall be incorporated in the submission:**

1. See RFI Log attached.
2. Pricing Workbook has been revised based on RFI question #1.

**Shamona Kamm**

**Purchasing Agent II**

Capital Projects and Facilities Procurement

University of Connecticut



UNIVERSITY OF CONNECTICUT

REQUEST FOR PROPOSAL

REQUEST FOR INFORMATION QUESTION AND ANSWER LOG

PROJECT/CONTRACT NAME: Generator Maintenance and Repairs

PROJECT/CONTRACT NUMBER: SK120721

DATE: 3/22/2022

RFI NO.	QUESTION	ANSWER
1	Do you want a price total for all units or for each individual unit? Please clarify the pricing sheet.	Price per individual unit
2	Do you require a load bank for all units and if so what are the voltages and amperages of the units? Is there any units that are elevated or located on roof tops?	Load bank not required, however availability should be made per the contract RFP. Load bank size to be determined by the provider based the individual unit model. Units are ground mounted or on their belly tanks.
3	Do you require fuel and oil testing to be included or just the oil testing?	Both, priced individually
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		



**UNIVERSITY OF CONNECTICUT**

REQUEST FOR PROPOSAL

**REQUEST FOR INFORMATION QUESTION AND ANSWER LOG**

PROJECT/CONTRACT NAME: Generator Maintenance and Repairs

PROJECT/CONTRACT NUMBER: SK120721

DATE: 3/22/2022

15		
16		
17		
18		
19		
20		